Cervi

Quality Department

DECLARATION OF PERFORMACE nºCPR-078

1 – Code of the product-type: **F-078**

CERVIFLEX VHOVMV-K 300/500V
Section range: from 0,50mm² to 2,5mm²

2 – Intended use/s:

Armored and shielded flexible cable for instrumentation and control applications in fixed installations, subject to fire reaction requirements for general applications in construction and civil engineering.

3 – Manufacturer:

CERVI SA, C/Libra 61 Pol.Ind.Can Parellada, 08228-Terrassa, Barcelona, Spain
Tel: +34 937362730. E-mail: cervi@cervi.es

4 – System/s of AVCP:

System 3

5 – Harmonized standard: EN 50575:2014 +A1:2016

Notified body/ies: Nº1722 (CEIS)

6 – Declared performances:

Essential characteristics	System/s of AVCP	Performance	Harmonized standard
Reaction to fire	System 3	Eca	EN 50575:2014+A1:2016
Dangerous substances		NPD (*)	

(*) Non Performance declaraction

7 – The performance of the product identified above is in conformity with the set of declared performances. This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Signed for and on behalf of the manufacturer by
Terrassa (Barcelona) August 25th, 2017

Josep Reig
Quality Manager

CPR COMPLIANT
Construction Products Regulation
EN 50575